Legend: C=Compliant; NC=Not compliant; NA=Not applicable; IOU=Surveyor awaiting documentation

STANDARD - EPs	See Legend				Document / Requirement	Yes	No	
	C	NC	NA	IOU				
LS.01.01.01					**Buildings serving patients comply w/ NFPA 101 (2012)**			
EP 1					Individual assigned to assess Life Safety Code® compliance			
EP 2					Building Assessment to determine compliance with Life Safety (LS) chapter			
EP 3					Current and accurate drawings w/ fire safety features & related square footage a. Areas of building fully sprinklered (if building only partially sprinklered) b. Locations of all hazardous storage areas c. Locations of all fire-rated barriers d. Locations of all smoke-rated barriers e. Sleeping and non-sleeping suite boundaries, including size of identified suites f. Locations of designated smoke compartments g. Locations of chutes and shafts h. Any approved equivalencies or waivers			
EP 5					Deemed Hospitals:			

STANDARD - EPs	See Legend	Document / Requirement

STANDARD - EPs	See Legend				Document / Requirement	Frequency	Yes	No / Missing Date
	C	NC	NA	IOU				
EC.02.05.07					Emergency Power Systems are Maintained			

STANDARD - EPs	See Legend

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date
EC.02.05.01					**Manages risks associated with utility systems**			

temperature and humidity.

Note: For more information about areas designed for control of airborne contaminants, the basis for design compliance is the Guidelines for Design and Construction of Health Care Facilities, based on the edition used at the time of design (if available).

STANDARD - EPs	See Legend C NC NA	Document / Requirement	Yes	No

STANDARD - EPs	See Legend				Document / Requirement	Frequency	Yes	No / Missing Date
	C	NC	NA	IOU				
EC.02.04.03					Medical equipment inspection, testing and maintenance			

EP 3

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date
EC.02.05.05					Utility system Inspection, testing and maintenance			
COMMENTS: Refer to the Guidance on Use of Alternate Maintenance Activities and/or Schedules section when CAHs choose to employ alternate maintenance activities and/or schedules.								

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date
EC.02.01.01					The hospital manages safety and security risks.			
EP 1					The hospital implements its process to identify safety and security risks associated with the environment of care that could affect patients, staff, and other people coming to the hospital's facilities. Note: Risks are identified from internal sources such as ongoing monitoring of the environment, results of root cause analyses, results of proactive risk assessments of high-risk processes, and from credible external sources such as Sentinel Event Alerts.			
EP 3					The hospital takes action to minimize or eliminate identified safety and security risks in the physical environment.			
EP 9					The hospital has written procedures to follow in the event of a security incident, including an infant or pediatric abduction.			
EP 10					When a security incident occurs, the hospital follows its identified procedures.			

Note: EP's14 and 16 are covered by the clinical imaging tracer.

STANDARD – EPs	See Legend				Document / Requirement	Frequency	Yes	No / Missing Date
	C	NC	NA	IOU				
EC.01.01.01								

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date
EC.04.01.03					**The hospital plans activities to minimize risks in the environment of care. (DPUs only)**			
EP 2					The hospital uses the results of data analysis to identify opportunities to resolve environmental safety issues.			

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date

STANDARD - EPs	See Legend				Document / Requirement	Addressed in policy?		Implemented as required?	
	C	NC	NA	IOU		Yes	No	Yes	No
LS.01.02.01					Interim Life Safety Measures (ILSM)				
EP 12					Temporary systems tested and inspected monthly				
EP 13					Additional training on building deficiencies, construction hazards, temp measures				
EP 14					Training for impaired structural or impaired compartment fire safety features		EP 54		

STANDARD - EPs	See Legend C	NC	NA	IOU	Document / Requirement	Frequency	Yes	No / Missing Date
EC.02.02.01					**The hospital manages risks related to hazardous materials and waste.**			
EP 1					The hospital maintains a written, current inventory of hazardous materials and waste that it uses, stores, or generates. The only materials that need to be included on the inventory are those whose handling, use, and storage are addressed by law and regulation. (See also MM.01.01.03, EPs 1 and 2)			
EP 3					The hospital has written procedures, including the use of precautions and personal protective equipment, to follow in response to hazardous material and waste spills or exposures.			
EP 11					For managing hazardous materials and waste, the hospital has the permits, licenses, manifests, and safety data sheets required by law and regulation.			

COMMENTS:

Note EP's 6, 7, 8, 17, and 18 are covered under clinical tracers.